

The Town Board of the Town of Ballston met as the Board of Health at 6:30 p.m. on Tuesday evening, July 30, 2013 at the Town Hall on Charlton Road.

PRESENT: Patricia Southworth ----- Supervisor  
Mary Beth Hynes ----- Councilwoman  
Timothy Szczepaniak ----- Councilman  
William Goslin ----- Councilman  
Kelly Stewart ----- Councilwoman  
Thomas Johnson ----- Building Inspector  
Carol Shemo ----- Clerk  
Thomas Johnson ----- Building Inspector  
ABSENT: Murry Brower ----- Attorney

The Town received a request from Winifred MacCammon to replace a septic system at 178 Westside Drive, Ballston Lake (SBL 249.17-1-1.1).

Mr. Nicoll, the installer of the septic system, was present for Ms. MacCammon and the Engineer, Wayne Kant.

Mr. Kant recommends replacing the septic system with an upgraded Eljen system. The necessary separation distance cannot be achieved so the following variances will be required:

Field to Lake	80' proposed	100' required	20' variance is needed
Field to property line	5' proposed	10' required	5' variance needed

Councilman Szczepaniak asked Building Inspector Johnson for his comments on this septic system.

Building Inspector Johnson stated that the engineer does the best he can to fit a septic system on the lot.

**BOARD OF HEALTH RESOLUTION 13-003**

**APPROVE THE FOLLOWING VARIANCES FOR THE INSTALLATION OF A SEPTIC SYSTEM AT 178 WESTSIDE DRIVE: FIELD TO LAKE 20' VARIANCE GRANTED, FIELD TO PROPERTY LINE 5' VARIANCE GRANTED.**

A motion was made by Councilman Szczepaniak and seconded by Councilwoman Stewart to approve the following variances for the installation of a septic system at 178 Westside Drive, Ballston Lake, (SBL 249.17-1-1.1) field to lake 20' variance granted, field to property line 5' variance granted.

ADOPTED: Ayes 5 Supervisor Southworth, Councilwoman Hynes, Councilman Szczepaniak, Councilman Goslin and Councilwoman Stewart  
Nays 0

Mr. Pierce, of the Ballston Lake Improvement Association, presented a report detailing the levels of bacteria in the water samples taken from 54 sample sites on the lake. Results of the tests showed higher levels of total coliform.

A motion was made by Councilwoman Stewart and seconded by Councilman Goslin to adjourn the meeting

Respectfully submitted,

Carol R. Shemo  
Town Clerk